




**DELHI JAL BOARD: GNCTD  
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref. No. D.J.B/DTQC/Wzd./2025-26/Paid-51-52		
Location /Address of Sample	Rosary Senior Secondary School, Radio Colony, Kingsway Camp, Delhi-110009		
Letter Reference No.	RS/2025-26/7113	Ref. Letter Date	29.05.2025
Challan No.	74	Challan Date	29.05.2025
Sample Collection date	30.05.2025	Analysis start date	30.05.2025
Any other Information	--	Analysis end date	01.06.2025
		Reporting date	02.06.2025

**TEST RESULTS**

S.No	Parameters	Unit	As per the IS 10500		Inlet	Outlet (Drinking tap)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.2	1.6
4	pH at 25 °C	--	6.5-8.5	No relaxation	7.33	7.23
5	Electrical Conductivity	µS/cm	-	-	441	108
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	286	70
7	Total Alkalinity	mg/L	200(Max)	600(Max)	96	28
8	Total Hardness	mg/L	200(Max)	600(Max)	128	56
9	Calcium as Ca	mg/L	75(Max)	200(Max)	31.2	10.4
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	12	7.2
11	Iron	mg/L	1.0(Max)	No relaxation	0.10	0.04
12	Chloride	mg/L	250(Max)	1000(Max)	60	18
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.32	0.14
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	5.3	0.8
16	Sulphate	mg/L	200(Max)	400(Max)	42.1	12.6
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	0.46	BDL
18	Coliform Count at 37°(MPN)	/100 mL	Absent	No relaxation	0	0

\*BDL=Below Detection Limit

.....End of Report.....

**Remarks: Samples collected confirms specification for tested parameters and can be considered for the drinking purpose.**

Tested by  
Lab. Tech.

Verified for Chemical parameters  
Asstt. Chemist

Verified for MPN  
Asstt. Bact.


Authorized by  
Chemist

**ATTESTED**

Principal  
**ROSARY SR. SEC. SCHOOL**  
Radio Colony, Kingsway Camp,  
Delhi-110009

ACWA(WZD)

Asstt. Chief Water Analyst  
D.J.B. (Govt. of N.C.T. of Delhi)  
Water Works, Wazirabad



MUNICIPAL CORPORATION OF DELHI  
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)  
16 RAJ PUR ROAD, DELHI - 110054

DHO/CLZ/2025/638


Dated: 26/6/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Public Health department/CLZ, inspected the M/S Rosary Senior Secondary School situated at Radio Colony, Kingsway Camp, Delhi-110009 on 25.06.2025 and found that the school is running under sanitary & hygienic conditions from health point of view.


School has safe drinking water facilities for the students and members of staff of the institution and his maintaining the hygiene & sanitation condition in the school building & the campus.

The above Certificate is valid for one year from date of issue.

  
Dy. Health Officer  
Civil Lines Zone

Deputy Health Officer  
Civil Lines Zone  
Municipal Corporation of Delhi  
16, Rajpur Road, Delhi-110054

ATTESTED



Principal  
ROSARY SR. SEC. SCHOOL  
Radio Colony, Kingsway Camp,  
Delhi-110009

Principal,  
M/S Rosary Senior Secondary School  
at Radio Colony, Kingsway Camp,  
Delhi-110009.